



CAPACITY

FLOW MGD	FLOW GPM	HEAD IN.
0.01	6.94	0.69
0.02	13.89	1.06
0.03	20.83	1.36
0.04	27.78	1.61
0.05	34.72	1.84
0.06	41.66	2.04
0.07	48.61	2.23
0.08	55.55	2.41
0.09	62.50	2.57
0.10	69.44	2.73
0.15	104.16	3.40
0.20	138.88	3.95
0.25	173.60	4.43
0.30	208.32	4.85
0.35	243.04	5.25
0.40	277.76	5.63
0.45	312.48	5.99

D (6")




ANCHOR CLIP




END VIEW

BILL OF MATERIAL

1	Molded fiberglass polyester flume with smooth inside finish (white)
2	1"x 8" Solid PVC spacer rods with SS hardware and FRP anchor clips (see detail)
3	Optional 1 1/2" NPT socket for ultrasonic mounting pipe - Right or Left - (shown left)
4	Optional staff gauge - Right or Left - (shown left)



TOP VIEW



VIEW A-A

LEGEND

D	Effective measuring depth (6")
P	Point of measurement (reference)

8" PALMER-BOWLUS FLUME



WARMINSTER FIBERGLASS